

## Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
1		7.68				Y
8		7.72				Y
10		7.76				Y
14		7.75				Y
15		7.75				Y
19		7.83				Y
21		7.84				Y
27		7.88				Y
29		7.7				Y
(N = No = Excursion) <b>Total N's</b>						0

<Has sample met the minimums? **ENTRY POINT**

**PWS ID: 41** 0 0 5 6 7

**System Name:** Westwood

**Sample Period:** May 2025

**Number of excursions during this Sample Period =** 0

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.2  
 Alk  (Alkalinity)  
 PO4  (Orthophosphate)  
 Other  (\_\_\_\_\_)

**Print Name:** Curtis Olson

**Signature:** *Curtis Olson*

**Date:** 06/08/2025

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>