

# Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
1						
2						
3						
4						
5						
6		8.08				Y
7		8.11				Y
8						
9						
10		8.04				Y
11						
12						
13						
14						
15		8.03				Y
16						
17						
18						
19						
20		8.10				Y
21		8.03				Y
22						
23						
24		8.06				Y
25						
26		8.02				Y
27						
28						
29						
30						
31						

(N = No = Excursion)

Total N's

0

<Has sample  
met the  
minimums?

## ENTRY POINT

PWS ID: 41 

0	0	5	6	7
---	---	---	---	---

System Name: Westwood

Sample Period: NOV 2025

Number of excursions during this  
Sample Period = 0

(Number of locations when any WQP  
was less than the minimum.)

Note: Entry Point and Distribution  
Excursions are cumulative. Add Entry  
Point and Distribution Excursions to get  
total for sample period.

For OHA use only

Minimum Water Quality  
Parameters as set by

pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	(_____)

Print Name: Curtis Olson

Signature: Curtis Olson

Date: 12/05/2025

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>