



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2	7.4	30			Y
3					
4					
5					
6					
7					
8	7.4	30			Y
9					
10					
11					
12					
13					
14					
15					
16	7.4	30			Y
17					
18					
19					
20					
21					
22					
23	7.4	30			Y
24					
25					
26					
27					
28					
29					
30	7.3	30			Y
31					

<<Have minimums been met for this day?

County: Coos Agency: COOS COUNTY

ENTRY POINT

EP-A

PWS ID 4100573

SANDNWOOD MOBILE VILLA

Sample period: April 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0



Print Name: Cindy McMahon

Signature: Cindy McMahon

Date Phone#: 5-1-2022 541-404-3966

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0