

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4	30			Y
2					
3					
4					
5					
6					
7					
8	7.4	30			Y
9					
10					
11					
12					
13					
14					
15	7.3	30			
16					
17					
18					
19					
20					
21					
22	7.3	30			Y
23					
24					
25					
26					
27					
28					
29	7.3	30			Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	5	7	3
---	---	---	---	---

System Name: SAND-N-WOOD MOBILE VILLA

Entry Point: EP-A Pump House

Sample Period: APR 1 2023

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.0

 Alk

22.0

 (Alkalinity)
 PO4

-

 (Orthophosphate)
 Other

Print Name: Judy Thompson

Signature: Judy Thompson

Date: May 1st 2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0