

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | | | | | |
| 2 | | | | | |
| 3 | | | | | |
| 4 | | | | | |
| 5 | | | | | |
| 6 | 7.4 | 30 | | | Y |
| 7 | | | | | |
| 8 | | | | | |
| 9 | | | | | |
| 10 | | | | | |
| 11 | | | | | |
| 12 | | | | | |
| 13 | 7.4 | 30 | | | Y |
| 14 | | | | | |
| 15 | | | | | |
| 16 | | | | | |
| 17 | | | | | |
| 18 | | | | | |
| 19 | | | | | |
| 20 | 7.3 | 30 | | | Y |
| 21 | | | | | |
| 22 | | | | | |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | 7.3 | 30 | | | Y |
| 28 | | | | | |
| 29 | | | | | |
| 30 | | | | | |
| 31 | | | | | |

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 5 | 7 | 3 |
|---|---|---|---|---|

System Name: SAND-N-WOOD MOBILE VILLA

Entry Point: EP-A

Sample Period: APRil/2024
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

| | | |
|-------|------|------------------|
| pH | 7.0 | |
| Alk | 22.0 | (Alkalinity) |
| PO4 | - | (Orthophosphate) |
| Other | | (_____) |

Print Name: Judy Thompson

Signature: Judy Thompson

Date: May 15 / 2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's