

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.1	30			Y
4					
5					
6					
7	7.1	30			Y
8					
9					
10					
11	7.1	30			Y
12					
13					
14	7.1	30			Y
15					
16					
17					
18	7.2	30			Y
19					
20					
21	7.1	30			Y
22					
23					
24					
25	7.0	30			Y
26					
27					
28	7.2	30			Y
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 0 0 5 7 3

System Name: SAND-N-WOOD

Entry Point: PUMP HOUSE

Sample Period: OCTOBER 2025

Month/Year

Number of excursions* during this month: 0


(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

pH	
Alk	
PO4	
Other	(_____)

Print Name: TERESA ROMERO

Signature: Teresa Romero

Date: 11/9/2025

Send to DWP within 10 days after end of sampling period