



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2					
3					
4					
5					
6					
7	7.4	30			Y
8					
9					
10					
11					
12					
13					
14	7.4	30			Y
15					
16					
17					
18					
19					
20					
21	7.4	30			Y
22					
23					
24					
25					
26					
27					
28	7.4	30			Y
29					
30					
31					

<<Have minimums been met for this day?

County: Coos Agency: COOS COUNTY

ENTRY POINT

EP-A

PWS ID 4100573

SANDNWOOD MOBILE VILLA

Sample period: May 2022
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.0



Print Name: Cindy McMahon
 Signature: Cindy McMahon
 Date Phone#: 6/1/2022 541-404-3966

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0