

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.3	30			Y
4					
5					
6					
7					
8					
9					
10	7.3	30			Y
11					
12					
13					
14					
15					
16					Y
17	7.3	30			
18					
19					
20					
21					
22					
23					Y
24	7.3	30			
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	5	7	3
---	---	---	---	---

System Name: SAND-N-WOOD MOBILE VILLA

Entry Point: EP-A Pump House

Sample Period: June 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.0</u>	
Alk	<u>22.0</u>	(Alkalinity)
PO4	<u>-</u>	(Orthophosphate)
Other	<u> </u>	()

Print Name: Judy Thompson

Signature: Judy Thompson

Date: July 3rd 2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0