

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4	30			Y
2					
3					
4					
5					
6					
7					
8	7.4	30			Y
9					
10					
11					
12					
13					
14					
15	7.3	30			Y
16					
17					
18					
19					
20					
21					
22	7.4	30			Y
23					
24					
25					
26					
27					
28					
29	7.3	30			Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	5	7	3
---	---	---	---	---

System Name: SAND-N-WOOD MOBILE VILLA

Entry Point: EP-A Pump house

Sample Period: July 2023
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.0</td></tr></table>	7.0	
7.0			
Alk	<table border="1"><tr><td>22.0</td></tr></table>	22.0	(Alkalinity)
22.0			
PO4	<table border="1"><tr><td>-</td></tr></table>	-	(Orthophosphate)
-			
Other	<table border="1"><tr><td></td></tr></table>		(_____)

Print Name: Judy Thompson

Signature: Judy Thompson

Date: August 1, 2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0