

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.4	30			Y
5					
6					
7					
8					
9					
10					
11	7.3	30			Y
12					
13					
14					
15					
16					
17					
18	7.4	30			Y
19					
20					
21					
22					
23					
24					
25	7.3	30			Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	5	7	3
---	---	---	---	---

System Name: SAND-N-WOOD MOBILE VILLA

Entry Point: EP-A Pump House

Sample Period: August 2023  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<b>7.0</b>	
Alk	<b>22.0</b>	(Alkalinity)
PO4	-	(Orthophosphate)
Other		(_____)

Print Name: Judy Thompson

Signature: Judy Thompson

Date: Sept 1st 2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 3