

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.3	30			Y
7					
8					
9					
10					
11					
12					
13	7.4	30			Y
14					
15					
16					
17					
18					
19					
20	7.4	30			Y
21					
22					
23					
24					
25					
26					
27	7.4	30			Y
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	5	7	3
---	---	---	---	---

System Name: SAND-N-WOOD MOBILE VILLA

Entry Point: EP-A

Sample Period: July 1st 2024
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	22.0	(Alkalinity)
PO4	-	(Orthophosphate)
Other		(_____)

Print Name: Judy Thompson

Signature: Judy Thompson

Date: August 1st 2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's