

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	8.0	26.0			Y
6					
7					
8					
9					
10					
11	7.8	34.5			Y
12					
13					
14					
15					
16					
17					
18	7.9	36.0			Y
19					
20					
21					
22					
23					
24	7.7	33.5			Y
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT
EP-B**

PWS ID 4100580

NORTH CLACKAMAS COUNTY WC

Sample period: April 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 25.0 (Alkalinity)

Print Name: Joe Rogers
Signature: *Joe Rogers*
Date & Phone#: 5-4-21 503-572-0129

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0