

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.6	31.6			
8					
9					
10					
11					
12					
13					
14	7.9	43			
15					
16					
17					
18					
19					
20	7.8	35.3			
21					
22					
23					
24					
25					
26					
27	7.7	30.4			
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-B

PWS ID 4100580

NORTH CLACKAMAS COUNTY WC

Sample period: September 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH	7.5
Alk	25.0 (Alkalinity)

Print Name: Joe Rogers

Signature: [Signature]

Date & Phone#: 10-1-21 (503) 572-0129

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0