

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.8	39.5			Y
5					
6					
7					
8					
9					
10					
11	7.7	25.0			Y
12					
13					
14					
15					
16					
17					
18	7.7	25.1			Y
19					
20					
21					
22					
23					
24					
25	7.7	25			Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-B**

**PWS ID 4100580**

**NORTH CLACKAMAS COUNTY WC**

Sample period: 4/2022  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 

7.5
-----

  
 Alk 

25.0
------

 (Alkalinity)

Print Name: Jojo Rogers  
 Signature: [Signature]  
 Date & Phone#: 5-4-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0