

Day	pH	Alk	Phos	Other	Y/N
1	7.8	33.1			Y
2					
3					
4					
5					
6					
7					
8	7.8	33.9			Y
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22	7.7	34.5			Y
23					
24					
25					
26					
27					
28					
29	7.7	35.0			Y
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-B**

**PWS ID 4100580**

**NORTH CLACKAMAS COUNTY WC**

Sample period: 8/2022  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.5
Alk	25.0 (Alkalinity)

Print Name: Joe Rogers  
Signature: [Signature]  
Date & Phone#: 9-1-22 (503) 572-0129

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0