

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.6	33.8			Y
3					
4					
5					
6					
7					
8					
9	7.7	33.3			Y
10					
11					
12					
13					
14					
15					
16	7.6	36.0			Y
17					
18					
19					
20					
21					
22					
23	7.7	35.0			Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-B**

**PWS ID 4100580**

**NORTH CLACKAMAS COUNTY WC**

Sample period: 6/2024  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.5  
 Alk 25.0 (Alkalinity)

Print Name: JOE ROGERS

Signature: [Signature]

Date & Phone#: 7-03-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0