

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.8	34.0			
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17	7.8	32.7			
18					
19					
20					
21					
22					
23					
24					
25	7.6	34.0			
26					
27					
28					
29					
30	7.7	34.2			
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT  
EP-B**

**PWS ID 4100580**

**NORTH CLACKAMAS COUNTY WC**

Sample period: 9/24  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.5  
Alk 25.0 (Alkalinity)

Print Name: Joe ROGERS

Signature: [Signature]

Date & Phone#: 10-1-24 503-572-0129

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0