

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.7	25.7			Y
4					
5					
6					
7					
8					
9	8.1	32.0			Y
10					
11					
12					
13					
14	8.4	26.3			Y
15					
16					
17					
18					
19					
20					
21	8.3	27.6			Y
22					
23					
24					
25					
26					
27	8.0	29.5			Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT  
EP-B**

**PWS ID 4100580**

**NORTH CLACKAMAS COUNTY WC**

Sample period: 1 / 2025  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.5  
 Alk 25.0 (Alkalinity)

Print Name: Bret Bienerth

Signature: Bret Bienerth

Date & Phone#: 2-5-2025 971-356-6943

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0