

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9	7.89	36.5			Y
10					
11					
12					
13					
14					
15					
16	8.00	36.5			Y
17					
18					
19					
20					
21					
22					
23	7.93	34.3			Y
24					
25					
26					
27					
28					
29					
30	7.84	37.9			Y
31					

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-B

PWS ID 4100580

NORTH CLACKAMAS COUNTY WC

Sample period: 10/2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 25.0 (Alkalinity)

Print Name: Steve Prestwood

Signature: [Signature]

Date & Phone#: 11-5-25 503-723-3505

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0