



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.82	26.0			Y
7					
8					
9					
10					
11					
12	7.9	27.3			Y
13					
14					
15					
16					
17					
18					
19					
20	8.26	32.7			Y
21					
22					
23					
24					
25					
26	7.99	41.9			Y
27					
28					
29					
30					

(No = N =Excursion) Total N's 0

<<Have minimums been met for this day?	ENTRY POINT EP-B PWS ID 4100580 North Clackamas County WC
	Sample Period: November 2025 Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Reference	
Minimum Water Quality Parameter(s) as set by State:	
pH	7.5
Alk	25.0 (Alkalinity)

Print Name: Steve Presfwoog
Signature: Steve Presfwoog
Date & Phone #: 503 723 3505 12-3-25

Send to DWP within 10 days after end sampling period