



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3					Y
4	7.86	28.0			Y
5					Y
6					Y
7					Y
8					Y
9					Y
10	8.69	20.9			N
11		19.0			N
12					N
13	8.95	25.1			Y
14					Y
15					Y
16					Y
17	8.32				Y
18	9.14				Y
19					Y
20					Y
21					Y
22					Y
23					Y
24					Y
25					Y
26	9.22	32.0			Y
27					Y
28					Y
29					Y
30					Y
31	8.11	28.5			Y
(No = N =Excursion) Total N's					0

<<Have minimums been met for this day?	ENTRY POINT
	EP-B
	PWS ID 4100580
	North Clackamas County WC
Sample Period: <u>Dec 2025</u>	
Month/Year	

Number of excursions* during this month: 3

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Reference	
Minimum Water Quality Parameter(s) as set by State:	
pH	7.5
Alk	25.0 (Alkalinity)

Print Name: Steve Prestwood
 Signature: [Signature]
 Date & Phone #: 1-6-26 503-723-3505

Send to DWP within 10 days after end
sampling period