



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	8.00	25.9			Y
4					
5					
6					
7					
8					
9	8.38	26.5			Y
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20	8.34	25.5			Y
21					
22					
23					
24	8.11	26.2			Y
25					
26					
27					
28					
29					
30					
31					
(No = N =Excursion) Total N's					0

<<Have minimums been met for this day?	ENTRY POINT EP-B PWS ID 4100580
	North Clackamas County WC Sample Period: <u>March 2026</u> <small>Month/Year</small>

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Reference	
Minimum Water Quality Parameter(s) as set by State:	
pH	7.5
Alk	25.0 (Alkalinity)

Print Name: Brent Carrer
 Signature: [Signature]
 Date & Phone #: 4/1/26 (971) 4097902

Send to DWP within 10 days after end sampling period