

Day	pH	Alk	Phos	Other	Y/N
1	7.68				
2	7.84				
3	7.81				
4	7.62				
5	7.80				
6	7.82				
7	7.80				
8	7.71				
9	7.76				
10	7.68				
11	7.60				
12	7.61				
13	7.62				
14	7.65				
15	7.70				
16	7.67				
17	7.54				
18	7.45				
19	7.64				
20	7.62				
21	7.65				
22	7.60				
23	7.54				
24	7.42				
25	7.54				
26	7.44				
27	7.46				
28	7.50				
29	7.46				
30	7.65				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Oceanside Water District

Entry Point: Main Reservoir

Sample Period: June / 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: David L. Nordman

Signature: 

Date: 7/7/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's