

Day	pH	Alk	Phos	Other	Y/N
1	7.72				
2	7.70				
3	7.64	29			
4	7.75				
5	7.59				
6	7.56				
7	7.70				
8	7.68				
9	7.68				
10	7.70				
11	7.63				
12	7.43				
13	7.69				
14	7.76				
15	7.74				
16	7.70				
17	7.68	25			
18	7.54				
19	7.59				
20	7.71				
21	7.67				
22	7.69				
23	7.70				
24	7.64				
25	7.70				
26	7.71				
27	7.54				
28	7.63				
29	7.64				
30	7.62				
31	7.61				

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: Oceanside Water District

Entry Point: Main Reservoir

Sample Period: August / 2021  
Month/Year

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**


pH

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

Print Name: David L. Nordman

Signature: 

Date: 9/9/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's