

Day	pH	Alk	Phos	Other	Y/N
1	7.51				
2	7.46				
3	7.73				
4	7.60				
5	7.39				
6	7.65				
7	7.83				
8	7.81				
9	7.38	27.41			
10	7.31				
11	7.66				
12	7.44				
13	7.59				
14	7.65				
15	7.63				
16	7.67				
17	7.68				
18	7.61				
19	7.47				
20	7.63				
21	7.61	26.38			
22	7.70				
23	7.49				
24	7.47				
25	7.80				
26	7.41				
27	7.49				
28	7.45				
29	7.62				
30	7.42				
31	7.56				
No = N = Excursion) <b>Total N's</b>					

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100585**

**OCEANSIDE WATER DISTRICT**

**Sample period: March / 2022** \_\_\_\_\_  
 Month/Year

**Number of excursions during this month: 0**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3  
 Alk 25.0 (Alkalinity)

**Print Name: David L. Nordman** \_\_\_\_\_

**Signature:**  \_\_\_\_\_

**Date & Phone#: 4/10/2022 503-842-6462**

Send to DWP within 10 days after end of sampling period