

Day	pH	Alk	Phos	Other	Y/N
1	7.57				
2	7.42				
3	7.53				
4	7.39				
5	7.54				
6	7.55				
7	7.50				
8	7.33				
9	7.30				
10	7.42				
11	7.40				
12	7.53				
13	7.44	47.88			
14	7.39				
15	7.52				
16	7.41				
17	7.55				
18	7.46				
19	7.46	34.2			
20	7.50				
21	7.77				
22	7.60				
23	7.46				
24	7.54				
25	7.56				
26	7.55				
27	7.73				
28	7.59				
29	7.73				
30	7.58				
(No = N = Excursion) <b>Total N's</b>					

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT  
EP-A**

**PWS ID 4100585**

**OCEANSIDE WATER DISTRICT**

**Sample period: April / 2022**  
Month/Year

**Number of excursions during this month: 0**


*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.3
Alk	25.0 (Alkalinity)

**Print Name: David L. Nordman**

**Signature:** 

**Date & Phone#: 5/2/2022 503-842-6462**

Send to DWP within 10 days after end of sampling period