

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.52				Y
2	7.64				Y
3	7.52				Y
4	7.59				Y
5	7.66				Y
6	7.59				Y
7	7.58				Y
8	7.62				Y
9	7.62				Y
10	7.38				Y
11	7.38				Y
12	7.33	27.16			Y
13	7.38				Y
14	7.38				Y
15	7.40				Y
16	7.42				Y
17	7.50				Y
18	7.53				Y
19	7.53				Y
20	7.45				Y
21	7.50				Y
22	7.53				Y
23	7.51				Y
24	7.46				Y
25	7.64				Y
26	7.68				Y
27	7.66	27.36			Y
28	7.70				Y
29	7.55				Y
30	7.57				Y
31					

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: June / 2022



Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

7.3

Alk

25.0

 (Alkalinity)

Print Name: David L. Nordman

Signature: 

Date & Phone#: 7/5/2022 (503)842-6462

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

0
