

Day	pH	Alk	Phos	Other	Y/N
1	7.49				Y
2	7.45				Y
3	7.56				Y
4	7.50				Y
5	7.47				Y
6	7.45				Y
7	7.39				Y
8	7.41				Y
9	7.44				Y
10	7.54	27.36			Y
11	7.53				Y
12	7.53				Y
13	7.57				Y
14	7.55				Y
15	7.47				Y
16	7.70				Y
17	7.61				Y
18	7.65				Y
19	7.64				Y
20	7.62				Y
21	7.59				Y
22	7.59				Y
23	7.53				Y
24	7.61	27.36			Y
25	7.60				Y
26	7.62				Y
27	7.59				Y
28	7.60				Y
29	7.56				Y
30	7.66				Y
31	7.67				Y

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT
EP-A**

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: **October / 2022**
Month/Year

Number of excursions during this month: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3
Alk 25.0 (Alkalinity)

Print Name: David L. Nordman

Signature: 

Date & Phone#: 11/4/2022 (503)842-6462

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0