

Day	pH	Alk	Phos	Other	Y/N
1	7.72				Y
2	7.55				Y
3	7.79				Y
4	7.66	27.36			Y
5	7.67				Y
6	7.57				Y
7	7.61				Y
8	7.73				Y
9	7.61				Y
10	7.63				Y
11	7.48				Y
12	7.53				Y
13	7.76				Y
14	7.47				Y
15	7.58				Y
16	7.60				Y
17	7.58				Y
18	7.59	27.36			Y
19	7.55				Y
20	7.66				Y
21	7.48				Y
22	7.57				Y
23	7.56				Y
24	7.62				Y
25	7.45				Y
26	7.71				Y
27	7.68				Y
28	7.47				Y
29	7.53				Y
30	7.58				Y
31	7.72				Y

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100585**

**OCEANSIDE WATER DISTRICT**

**Sample period: December / 2023**  
 Month/Year

**Number of excursions during this month: 0**


*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3  
 Alk 25.0 (Alkalinity)

**Print Name:** David L. Nordman

**Signature:** 

**Date & Phone#:** 1/9 /2024 (503)842-6462

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0