

Day	pH	Alk	Phos	Other	Y/N
1	7.41				Y
2	7.52				Y
3	7.41				Y
4	7.61				Y
5	7.57				Y
6	7.62				Y
7	7.71				Y
8	7.73				Y
9	7.62				Y
10	7.63				Y
11	7.65				Y
12	7.46				Y
13	7.56				Y
14	7.73				Y
15	7.65	27.36			Y
16	7.56				Y
17	7.66				Y
18	7.66				Y
19	7.62				Y
20	7.63				Y
21	7.57				Y
22	7.56				Y
23	7.54				Y
24	7.55				Y
25	7.44				Y
26	7.50				Y
27	7.53				Y
28	7.57				Y
29	7.63	27.36			Y
30	7.61				Y
31	7.50				Y

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100585**

**OCEANSIDE WATER DISTRICT**

Sample period: **July 2024**       
 Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3  
 Alk 25.0 (Alkalinity)

Print Name: David L. Nordman

Signature: 

Date & Phone#: 8/7/2024 (503)842-6462

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0