

Day	pH	Alk	Phos	Other	Y/N
1	7.58	27.36			Y
2	7.64				Y
3	7.56				Y
4	7.67				Y
5	7.51				Y
6	7.58				Y
7	7.54				Y
8	7.40				Y
9	7.73				Y
10	7.66				Y
11	7.54				Y
12	7.49				Y
13	7.55				Y
14	7.51				Y
15	7.41				Y
16	7.53	27.36			Y
17	7.63				Y
18	7.58				Y
19	7.55				Y
20	7.67				Y
21	7.59				Y
22	7.53				Y
23	7.47				Y
24	7.39				Y
25	7.42				Y
26	7.40				Y
27	7.43				Y
28	7.45				Y
29	7.41				Y
30	7.43	27.36			Y

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100585**

**OCEANSIDE WATER DISTRICT**

**Sample period: September 2024** \_\_\_  
 Month/Year

**Number of excursions during this month: 0**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3  
 Alk 25.0 (Alkalinity)

**Print Name:** David L. Nordman

**Signature:** 

**Date & Phone#:** 10/8/2024 (503)842-6462

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0