

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.73				Y
2	7.65				Y
3	7.77				Y
4	7.90				Y
5	7.64				Y
6	7.64	27.36			Y
7	7.64				Y
8	7.55				Y
9	7.60				Y
10	7.40				Y
11	7.48				Y
12	7.54				Y
13	7.51	27.36			Y
14	7.59				Y
15	7.66				Y
16	7.44				Y
17	7.59				Y
18	7.59				Y
19	7.63				Y
20	7.88	27.36			Y
21	7.69				Y
22	7.84				Y
23	7.71				Y
24	7.73				Y
25	7.48				Y
26	7.48				Y
27	7.74	27.36			Y
28	7.76				Y
29	7.74				Y
30	7.77				Y
					Y

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: April/2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3
Alk 25.0 (Alkalinity)

Print Name: Christian Anderson

Signature: 

Date & Phone#: (503)842-6462

Send to DWP within 10 days after end of
sampling period