

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.63				Y
2	7.59	27.36			Y
3	7.78				Y
4	7.63				Y
5	7.68				Y
6	7.62				Y
7	7.68				Y
8	7.69				Y
9	7.71	27.36			Y
10	7.63				Y
11	7.59				Y
12	7.66				Y
13	7.62				Y
14	7.68				Y
15	7.68				Y
16	7.60	27.36			Y
17	7.62				Y
18	7.60				Y
19	7.60				Y
20	7.66				Y
21	7.65				Y
22	7.56				Y
23	7.58	27.36			Y
24	7.50				Y
25	7.61				Y
26	7.61				Y
27	7.50				Y
28	7.60				Y
29	7.61				Y
30	7.62	27.36			Y

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: June/2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3

Alk 25.0 (Alkalinity)

Print Name: Christian Anderson

Signature: 

Date & Phone#: _____ (503)842-6462

Send to DWP within 10 days after end of
sampling period