

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.61				Y
2	7.55				Y
3	7.56				Y
4	7.57	27.36			Y
5	7.57				Y
6	7.59				Y
7	7.53				Y
8	7.66				Y
9	7.57				Y
10	7.55				Y
11	7.46	27.36			Y
12	7.54				Y
13	7.54				Y
14	7.50				Y
15	7.46				Y
16	7.63				Y
17	7.49				Y
18	7.60	27.36			Y
19	7.64				Y
20	7.53				Y
21	7.54				Y
22	7.59				Y
23	7.59				Y
24	7.58				Y
25	7.64	27.36			Y
26	7.65				Y
27	7.65				Y
28	7.62				Y
29	7.62				Y
30	7.52				Y
31	7.55				Y

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: August/2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3
Alk 25.0 (Alkalinity)

Print Name: Christian Anderson

Signature: 

Date & Phone#: _____ (503)842-6462

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>