



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.54				Y
2	7.46				Y
3	7.52				Y
4	7.51				Y
5	7.46				Y
6	7.46	27.36			Y
7	7.47				Y
8	7.53				Y
9	7.51				Y
10	7.52				Y
11	7.49				Y
12	7.44				Y
13	7.4	27.36			Y
14	7.45				Y
15	7.44				Y
16	7.5				Y
17	7.51				Y
18	7.5				Y
19	7.52				Y
20	7.55	27.36			Y
21	7.51				Y
22	7.53				Y
23	7.46				Y
24	7.52				Y
25	7.57				Y
26	7.54				Y
27	7.60	27.36			Y
28	7.42				Y
29	7.83				Y
30	7.66				Y
31	7.65				Y

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: October/2025

Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH
Alk (Alkalinity)

Print Name: Christian Anderson

Signature:

Date & Phone#: (503)842-6462

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>