

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.58				Y
2	7.53				Y
3	7.42	27.36			Y
4	7.62				Y
5	7.56				Y
6	7.55				Y
7	7.70				Y
8	7.61				Y
9	7.74				Y
10	7.56	27.36			Y
11	7.56				Y
12	7.63				Y
13	7.50				Y
14	7.52				Y
15	7.54				Y
16	7.64				Y
17	7.46	27.36			Y
18	7.56				Y
19	7.49				Y
20	7.51				Y
21	7.62				Y
22	7.58				Y
23	7.42				Y
24	7.48	27.36			Y
25	7.44				Y
26	7.42				Y
27	7.59				Y
28	7.49				Y
29	7.48				Y
30	7.49				Y

<<Have
minimums
been met for
this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: November/2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3

Alk 25.0 (Alkalinity)

Print Name: Christian Anderson

Signature: 

Date & Phone#: _____ (503)842-6462

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0