Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.50				Y
2	7.44	27.36			Y
3	7.66				Y
4	7.67				Y
5	7.68				Y
6	7.71				Y
7	7.62				Y
8	7.67				Y
9	7.68	27.36			Y
10	7.83				Y
11	7.35				Y
12	7.4				Y
13	7.74				Y
14	7.61				Y
15	7.86				Y
16	7.70	27.36			Y
17	7.73				Y
18	7.64				Y
19	7.37				Y
20	7.41				Y
21	7.73				Y
22	7.74				Y
23	7.47	27.36			Y
24	7.54				Y
25	7.55				Y
26	7.69				Y
27	7.60				Y
28	7.62				Y
29	7.66				Y
30	7.33	27.36			Y
31	7.60				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: March/2026

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.3

Alk 25.0 *(Alkalinity)*

Print Name: Christian Anderson

Signature:

Date & Phone#: 04/01/2026 (503)842-6462

Send to DWP within 10 days after end of sampling period