

Day	pH	Alk	Phos	Other	Y/N
1	7.78				
2	7.72				
3	7.74				
4	7.70				
5	7.74				
6	7.79				
7	7.73				
8	7.50				
9	7.80				
10	7.78				
11	7.77				
12	7.74				
13	7.72				
14	7.86				
15	7.67				
16	7.89				
17	7.72				
18	7.73				
19	7.74				
20	7.70				
21	7.75				
22	7.77				
23	7.73				
24	7.62				
25	7.64				
26	7.60				
27	7.64				
28	7.59				
29	7.69				
30	7.70				
31	7.53				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Oceanside Water District

Entry Point: Main Reservoir

Sample Period: January / 2021  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**


pH

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

Print Name: David L. Nordman

Signature: 

Date: 2/8/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's