

Day	pH	Alk	Phos	Other	Y/N
1	7.70				
2	7.64				
3	7.82				
4	7.84				
5	7.73				
6	7.68				
7	7.90				
8	7.86				
9	7.93				
10	7.92				
11	7.91				
12	7.81				
13	7.61				
14	7.67				
15	7.96				
16	7.88				
17	7.88				
18	7.33				
19	7.67				
20	7.54				
21	7.36				
22	7.64				
23	7.56				
24	7.76				
25	7.85				
26	7.74				
27	7.84				
28	7.79				
29	7.72				
30	7.80				
31	7.87				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Oceanside Water District

Entry Point: Main Reservoir

Sample Period: March / 2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: David L. Nordman

Signature: 

Date: 4/6/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's