

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
	7.72				
	7.68				
	7.52				
	7.59				
	7.66				
	7.43				
	7.40				
	7.44				
	7.38				
0	7.41				
1	7.46				
2	7.38				
3	7.76				
4	7.74				
5	7.96				
6	7.91				
7	7.34				
8	7.39				
9	7.63				
0	7.47				
1	7.74				
2	7.46				
3	7.62				
4	7.35				
5	7.85				
6	7.35				
7	7.65				
8	7.76				
9	7.85				
0	7.67				
1	7.60				

o = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID:** 41 0 0 5 8 5

**System Name:** Oceanside Water District

**Entry Point:** Main Reservoir

**Sample Period:** January/ 2022  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**


pH 7.3

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

**Print Name:** David L. Nordman

**Signature:** 

**Date:** 2/8/2022

Send to DWP within 10 days after end of sampling period