

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.75				Y
2	7.70				Y
3	7.78	27.36			Y
4	7.86				Y
5	7.70				Y
6	7.66				Y
7	7.64				Y
8	7.65				Y
9	7.74				Y
10	7.69				Y
11	7.63				Y
12	7.74				Y
13	7.73				Y
14	7.77				Y
15	7.76				Y
16	7.71				Y
17	7.50	27.36			Y
18	7.65				Y
19	7.58				Y
20	7.56				Y
21	7.61				Y
22	7.60				Y
23	7.67				Y
24	7.60				Y
25	7.46				Y
26	7.42				Y
27	7.55				Y
28	7.60				Y
29	7.68				Y
30	7.76				Y
31	7.81	27.36			

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT
EP-A**

PWS ID 4100585

OCEANSIDE WATER DISTRICT

Sample period: **July / 2023**
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3
 Alk 25.0 (Alkalinity)

Print Name: David L. Nordman

Signature: 

Date & Phone#: 8/9/2023 (503)842-6462

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0