

Day	pH	Alk	Phos	Other	Y/N
1	7.46				Y
2	7.47				Y
3	7.48				Y
4	7.77				Y
5	7.74				Y
6	7.59	27.36			Y
7	7.76				Y
8	7.58				Y
9	7.65				Y
10	7.70				Y
11	7.66				Y
12	7.68				Y
13	7.54				Y
14	7.80				Y
15	7.58				Y
16	7.42				Y
17	7.57				Y
18	7.53				Y
19	7.55				Y
20	7.30	27.36			Y
21	7.45				Y
22	7.54				Y
23	7.51				Y
24	7.61				Y
25	7.62				Y
26	7.67				Y
27	7.56				Y
28	7.70				Y
29	7.67				Y
30	7.69				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?	County: Tillamook Agency: REGION 1 <b>ENTRY POINT</b> <b>EP-A</b> <b>PWS ID 4100585</b> <b>OCEANSIDE WATER DISTRICT</b>  Sample period: <b>November / 2023</b> ____ <i>Month/Year</i>
--	--

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3

Alk 25.0 (Alkalinity)

**Print Name:** David L. Nordman  
**Signature:**   
**Date & Phone#:** 12/10 /2023 (503)842-6462

Send to DWP within 10 days after end of sampling period