

Day	pH	Alk	Phos	Other	Y/N
1	7.43				Y
2	7.45				Y
3	7.47				Y
4	7.54				Y
5	7.49				Y
6	7.55				Y
7	7.55				Y
8	7.51				Y
9	7.68				Y
10	7.74				Y
11	7.88				Y
12	7.73	27.36			Y
13	7.60				Y
14	7.59				Y
15	7.63				Y
16	7.63				Y
17	7.60				Y
18	7.46				Y
19	7.52				Y
20	7.66				Y
21	7.46				Y
22	7.50				Y
23	7.51				Y
24	7.41				Y
25	7.36				Y
26	7.56	27.36			Y
27	7.47				Y
28	7.38				Y
29	7.67				Y
30	7.60				Y
31	7.58				Y

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100585**

**OCEANSIDE WATER DISTRICT**

**Sample period: August 2024**  
*Month/Year*

**Number of excursions during this month: 0**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3  
 Alk 25.0 (Alkalinity)

**Print Name:** David L. Nordman

**Signature:**

**Date & Phone#:** 9/10/2024 (503)842-6462

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0