

**OHA Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6	24.0	/	/	Y
2	7.7	25.5	/	/	Y
3	7.7	22.5	/	/	Y
4	7.7	22.8	/	/	Y
5	7.6	21.5	/	/	Y
6	7.6	22.0	/	/	Y
7	7.7	22.5	/	/	Y
8	7.8	24.0	/	/	Y
9	7.9	23.8	/	/	Y
10	7.9	23.1	/	/	Y
11	8.1	22.1	/	/	Y
12	7.7	22.5	/	/	Y
13	7.4	21.0	/	/	*N
14	7.5	23.0	/	/	Y
15	8.5	26.5	/	/	Y
16	7.9	24.0	/	/	Y
17	7.7	22.5	/	/	Y
18	7.7	23.0	/	/	Y
19	7.8	22.0	/	/	Y
20	7.5	23.5	/	/	Y
21	7.8	23.5	/	/	Y
22	8.0	23.5	/	/	Y
23	7.8	26.0	/	/	Y
24	7.9	23.3	/	/	Y
25	7.6	25.5	/	/	Y
26	7.5	24.0	/	/	Y
27	7.6	25.5	/	/	Y
28	7.6	26.0	/	/	Y
29	7.9	29.0	/	/	Y
30	7.7	25.0	/	/	Y
31	7.8	26.7	/	/	Y
<b>(No = N = Excursion) Total N's</b>					1

<< Have minimums been met for this day

**ENTRY POINT**

**A**

**PWS ID 4100591**

**OREGON CITY - SOUTH FORK W B**

Sample Period: January 2021

Month/Year

Number of excursions\* during this month: 1  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

**Reference**

Minimum Water Quality Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Katelynn Niece

Signature: *Katelynn Niece*

Date: February 1, 2021

Phone #: 503-657-5030

**\*Note: Excursion resulted from storm event with turbidity in excess of 300ntu.**