

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.7	25.7	/	/	Y
2	7.8	25.0	/	/	Y
3	7.5	24.0	/	/	Y
4	7.5	25.0	/	/	Y
5	7.6	24.0	/	/	Y
6	7.8	24.6	/	/	Y
7	7.8	25.2	/	/	Y
8	7.8	26.0	/	/	Y
9	7.6	24.5	/	/	Y
10	7.7	26.0	/	/	Y
11	7.8	27.0	/	/	Y
12	7.6	22.0	/	/	Y
13	*N/A	*N/A	/	/	*N/A
14	*N/A	*N/A	/	/	*N/A
15	*N/A	*N/A	/	/	*N/A
16	*N/A	*N/A	/	/	*N/A
17	7.5	22.0	/	/	Y
18	7.5	22.5	/	/	Y
19	7.8	22.5	/	/	Y
20	7.8	22.0	/	/	Y
21	7.8	22.8	/	/	Y
22	7.7	21.5	/	/	Y
23	8.0	23.5	/	/	Y
24	7.8	22.5	/	/	Y
25	7.8	22.0	/	/	Y
26	7.8	25.0	/	/	Y
27	7.8	22.5	/	/	Y
28	8.0	23.5	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day


<p>ENTRY POINT A PWS ID 4100591 OREGON CITY - SOUTH FORK W B Sample Period: <u>February 2021</u> Month/Year</p>

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Katelynn Niece
Signature: 
Date: March 1, 2021
Phone #: 503-657-5030

*N/A: Power Outage occurring from storm event.