

## OHA Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6	23.0	/	/	Y
2	7.7	24.0	/	/	Y
3	8.1	25.0	/	/	Y
4	7.7	24.5	/	/	Y
5	8.0	25.5	/	/	Y
6	8.1	25.0	/	/	Y
7	8.0	26.0	/	/	Y
8	7.7	24.5	/	/	Y
9	7.8	26.0	/	/	Y
10	7.6	24.0	/	/	Y
11	7.7	24.5	/	/	Y
12	7.7	23.5	/	/	Y
13	7.8	25.0	/	/	Y
14	7.9	25.0	/	/	Y
15	7.8	24.0	/	/	Y
16	7.9	26.0	/	/	Y
17	7.9	23.5	/	/	Y
18	7.7	24.0	/	/	Y
19	7.8	24.0	/	/	Y
20	7.7	24.0	/	/	Y
21	7.8	23.5	/	/	Y
22	7.8	24.0	/	/	Y
23	7.9	23.5	/	/	Y
24	7.7	23.5	/	/	Y
25	7.8	23.0	/	/	Y
26	7.7	22.2	/	/	Y
27	7.7	22.9	/	/	Y
28	7.6	23.1	/	/	Y
29	7.7	23.0	/	/	Y
30	8.1	22.5	/	/	Y
31	8.0	23.0	/	/	Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

**ENTRY POINT**  
**A**  
**PWS ID 4100591**  
**OREGON CITY - SOUTH FORK W B**  
Sample Period: March 2021  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 1  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? **Y**

**Reference**

Minimum Water Quality Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Katelynn Niece

Signature: *Katelynn Niece*

Date: April 1, 2021

Phone #: 503-657-5030