

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.7	22.0	/	/	Y
2	8.1	24.0	/	/	Y
3	7.9	24.0	/	/	Y
4	7.9	24.0	/	/	Y
5	7.9	23.0	/	/	Y
6	7.9	22.5	/	/	Y
7	7.6	22.0	/	/	Y
8	7.9	24.0	/	/	Y
9	7.8	25.0	/	/	Y
10	7.8	26.8	/	/	Y
11	7.8	23.0	/	/	Y
12	7.7	23.0	/	/	Y
13	7.6	23.0	/	/	Y
14	7.7	24.0	/	/	Y
15	7.8	23.5	/	/	Y
16	7.9	23.0	/	/	Y
17	7.7	24.5	/	/	Y
18	7.7	23.0	/	/	Y
19	8.0	28.5	/	/	Y
20	7.6	24.0	/	/	Y
21	7.5	22.5	/	/	Y
22	7.5	24.0	/	/	Y
23	7.7	22.5	/	/	Y
24	7.7	22.5	/	/	Y
25	7.9	22.5	/	/	Y
26	7.7	24.0	/	/	Y
27	7.9	27.5	/	/	Y
28	7.7	23.0	/	/	Y
29	7.7	25.0	/	/	Y
30	7.8	24.5	/	/	Y

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>April 2021</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Katelynn Niece

Signature: *Katelynn Niece*

Date: May 3, 2021

Phone #: 503-657-5030

(No = N = Excursion) Total N's 0