

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.8	24.0	/	/	Y
2	7.9	24.2	/	/	Y
3	7.7	22.5	/	/	Y
4	7.7	23.5	/	/	Y
5	7.7	22.0	/	/	Y
6	7.8	24.0	/	/	Y
7	7.6	22.0	/	/	Y
8	7.9	22.5	/	/	Y
9	7.7	22.0	/	/	Y
10	7.6	23.0	/	/	Y
11	7.8	23.5	/	/	Y
12	7.7	24.0	/	/	Y
13	7.6	23.0	/	/	Y
14	7.6	24.5	/	/	Y
15	7.6	23.5	/	/	Y
16	7.7	23.0	/	/	Y
17	7.5	23.0	/	/	Y
18	7.6	27.0	/	/	Y
19	7.7	25.0	/	/	Y
20	7.6	23.0	/	/	Y
21	7.5	24.0	/	/	Y
22	7.6	23.0	/	/	Y
23	7.7	24.5	/	/	Y
24	7.5	23.0	/	/	Y
25	7.7	24.0	/	/	Y
26	7.6	23.0	/	/	Y
27	7.6	25.5	/	/	Y
28	7.6	22.5	/	/	Y
29	7.8	27.0	/	/	Y
30	7.7	23.0	/	/	Y
31	7.6	23.0	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT

A

PWS ID 4100591

OREGON CITY - SOUTH FORK W B

Sample Period: May 2021

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)


Is system in compliance? Y

Reference

Minimum Water Quality Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Katelynn Niece

Signature: 

Date: June 1, 2021

Phone #: 503-657-5030