

**OHA Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6	26.5	/	/	Y
2	7.6	25.0	/	/	Y
3	7.7	24.0	/	/	Y
4	7.5	25.0	/	/	Y
5	7.5	26.0	/	/	Y
6	7.5	26.0	/	/	Y
7	7.6	25.5	/	/	Y
8	7.5	26.5	/	/	Y
9	7.6	25.5	/	/	Y
10	7.4	26.0	/	/	N
11	7.5	25.0	/	/	Y
12	7.7	24.5	/	/	Y
13	7.6	24.5	/	/	Y
14	7.6	24.5	/	/	Y
15	7.7	25.0	/	/	Y
16	7.7	26.0	/	/	Y
17	7.6	28.0	/	/	Y
18	7.7	28.0	/	/	Y
19	7.6	29.5	/	/	Y
20	7.5	30.5	/	/	Y
21	7.6	28.0	/	/	Y
22	7.7	31.5	/	/	Y
23	7.5	29.0	/	/	Y
24	7.6	29.5	/	/	Y
25	7.5	28.5	/	/	Y
26	7.5	28.5	/	/	Y
27	7.5	30.5	/	/	Y
28	7.6	32.0	/	/	Y
29	7.6	33.5	/	/	Y
30	7.6	30.5	/	/	Y

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
Sample Period: <u>June 2021</u>
Month/Year

Number of excursions\* during this month: 1  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 1  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? **Y**

<b>Reference</b>	
Minimum Water Quality Parameters as set by State:	
pH <table border="1"><tr><td>7.5</td></tr></table>	7.5
7.5	
Alk <table border="1"><tr><td>20.0</td></tr></table>	20.0
20.0	

Print Name: Katelynn Niece

Signature: *Katelynn Niece*

Date: July 1, 2021

Phone #: 503-657-5030

(No = N = Excursion) Total N's 1