

OHA Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	30.0			Y
2	7.6	29.0			Y
3	7.6	31.0			Y
4	7.6	31.0			Y
5	7.6	32.5			Y
6	7.6	30.0			Y
7	7.5	31.0			Y
8	7.5	35.3			Y
9	7.6	33.5			Y
10	7.6	32.1			Y
11	7.6	32.5			Y
12	7.6	32.0			Y
13	7.5	31.0			Y
14	7.6	31.0			Y
15	7.7	34.0			Y
16	7.6	30.5			Y
17	7.7	31.5			Y
18	7.6	29.5			Y
19	7.6	28.0			Y
20	7.7	34.0			Y
21	7.7	31.0			Y
22	7.6	31.5			Y
23	7.6	31.5			Y
24	7.5	30.0			Y
25	7.5	30.5			Y
26	7.6	31.0			Y
27	7.6	31.5			Y
28	7.7	33.5			Y
29	7.7	32.5			Y
30	7.7	32.5			Y
31	7.6	31.5			Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: July 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Katelynn Niece
Signature: *Katelynn Niece*
Date: August 3, 2021
Phone #: 503-657-5030